

## Test Documents for Vacuum Circuit-Breaker 3AH5273-4 (24 kV, 20 kA, 2000 A)

The vacuum circuit-breakers of type 3AH5 were type tested in accordance with

IEC 60694, edition 2.2, 2002-01,  
IEC 62271-100, 1st edition, 2001-05 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AH5273-4 the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	U <sub>p</sub> = 125 kV U <sub>d</sub> = 50 kV	03-036-MH/E
Temperature-rise tests	I <sub>r</sub> = 2000 A	03-010-ME/E
Mechanical operation test at ambient temperature, Low and high temperature tests	10.000 op. Cycles	03-011-MM/E
Short-time withstand current and peak withstand current tests	I <sub>sc</sub> = 20 kA/3s I <sub>ma</sub> = 50 kA	03-021-MS/E
Short-circuit making and breaking tests	I <sub>sc</sub> = 20 kA I <sub>ma</sub> = 50 kA	03-021-MS/E



Anger  
Head of Medium Voltage Components  
Research, Development & Testing Department



Berlin, November 28, 2006

**Siemens AG**  
Geschäftsgebiet: Medium Voltage  
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard  
Bereich: Power Transmission and Distribution  
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:  
Siemens AG  
PTD M C R&D  
13623 Berlin

Hausadresse:  
Nonnendammallee 104  
Siemensstadt  
13629 Berlin  
Tel: +49 (30) 386-0

Test Documents  
for Vacuum Circuit-Breaker  
3AH5273-4  
(24 kV, 20 kA, 2000 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.



Anger  
Head of Medium Voltage Components  
Research, Development & Testing Department



Berlin, November 28, 2006

**Siemens AG**  
Geschäftsgebiet: Medium Voltage  
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard  
Bereich: Power Transmission and Distribution  
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:  
Siemens AG  
PTD M C R&D  
13623 Berlin

Hausadresse:  
Nonnendammallee 104  
Siemensstadt  
13629 Berlin  
Tel: +49 (30) 386-0

## Test Documents for Vacuum Circuit-Breaker 3AH5273-4 (24 kV, 20 kA, 2000 A)

In addition to the type tests in accordance with IEC 60694 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	03-021-MS/E
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	03-032-MS/E
Out-of-phase making and breaking tests	03-045-MS/E



Anger  
Head of Medium Voltage Components  
Research, Development & Testing Department



Berlin, November 28, 2006

**Siemens AG**  
Geschäftsgebiet: Medium Voltage  
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard  
Bereich: Power Transmission and Distribution  
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:  
Siemens AG  
PTD M C R&D  
13623 Berlin

Hausadresse:  
Nonnendammallee 104  
Siemensstadt  
13629 Berlin  
Tel: +49 (30) 386-0