


Test Documents for Vacuum Circuit-Breaker 3AH5283-4 (24 kV, 20 kA, 2000 A)

The vacuum circuit-breakers of type 3AH5 were type tested in accordance with

IEC 60694, edition 2.2, 2002-01,
IEC 62271-100, 1st edition, 2001-05 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AH5283-4 the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	$U_p = 125 \text{ kV}$ $U_d = 50 \text{ kV}$	03-028-MH/E
Temperature-rise tests	$I_r = 2000 \text{ A}$	03-010-ME/E
Mechanical operation test at ambient temperature, Low and high temperature tests	10.000 op. Cycles	03-011-MM/E
Short-time withstand current and peak withstand current tests	$I_{sc} = 20 \text{ kA/3s}$ $I_{ma} = 50 \text{ kA}$	03-021-MS/E
Short-circuit making and breaking tests	$I_{sc} = 20 \text{ kA}$ $I_{ma} = 50 \text{ kA}$	03-021-MS/E



Anger
Head of Medium Voltage Components
Research, Development & Testing Department



Berlin, November 28, 2006

Siemens AG
Geschäftsgebiet: Medium Voltage
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard
Bereich: Power Transmission and Distribution
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:
Siemens AG
PTD M C R&D
13623 Berlin

Hausadresse:
Nonnendammallee 104
Siemensstadt
13629 Berlin
Tel: +49 (30) 386-0

Test Documents
for Vacuum Circuit-Breaker
3AH5283-4
(24 kV, 20 kA, 2000 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.



Anger
Head of Medium Voltage Components
Research, Development & Testing Department



Berlin, November 28, 2006

Siemens AG
Geschäftsgebiet: Medium Voltage
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard
Bereich: Power Transmission and Distribution
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:
Siemens AG
PTD M C R&D
13623 Berlin

Hausadresse:
Nonnendammallee 104
Siemensstadt
13629 Berlin
Tel: +49 (30) 386-0

Test Documents for Vacuum Circuit-Breaker 3AH5283-4 (24 kV, 20 kA, 2000 A)

In addition to the type tests in accordance with IEC 60694 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	03-021-MS/E
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	03-032-MS/E
Out-of-phase making and breaking tests	03-045-MS/E



Anger
Head of Medium Voltage Components
Research, Development & Testing Department



Berlin, November 28, 2006

Siemens AG
Geschäftsgebiet: Medium Voltage
Leitung: Wolfgang Heuring, Kfm. Leitung: Norbert Reinhard
Bereich: Power Transmission and Distribution
Vorstand: Udo Niehage, Vorsitzender; Pamela Knapp, Christian Urbanke

Briefadresse:
Siemens AG
PTD M C R&D
13623 Berlin

Hausadresse:
Nonnendammallee 104
Siemensstadt
13629 Berlin
Tel: +49 (30) 386-0