SIEMENS

Data sheet

5SV5646-6



Residual current operated circuit breaker, 4-pole, Type A, In: 63A, 300mA, Un AC: 400V Residential

Model				
product brand name	SENTRON			
product designation	RCCB			
design of the product	Instantaneous			
product type designation	5SV5			
General technical data				
number of poles	4			
size of installation devices according to DIN 43880	1			
mechanical service life (operating cycles) typical	3 000			
short-circuit current of series fuse maximum permissible	80 A			
short-circuit current rating	6 kA			
switching function short-term delayed	No			
overvoltage category	III			
Supply voltage				
supply voltage for testing equipment minimum	100 V			
value range of the supply voltage frequency	50 Hz			
value range of the operating frequency	50 Hz			
value range of the supply voltage at AC	230/400 V			
Protection class				
protection class IP	IP20, if the distribution board is installed, with connected conductors			
Switching capacity				
switching capacity current				
 according to IEC 61008-1 rated value 	0.8 kA			
Dissipation				
power loss [W]				
 for rated value of the current at AC in hot operating state per pole 	4.1 W			
• maximum	12.3 W			
Product details				
product feature silicon-free	Yes			
product extension installable supplementary devices	No			
Connections				
connectable conductor cross-section solid				
• minimum	0.75 mm²			
• maximum	35 mm²			
connectable conductor cross-section stranded				
• minimum	0.75 mm²			
• maximum	35 mm²			
tightening torque with screw-type terminals				

• maximum	• maximum		3 N·m			
position of power supply cord		top or bottom				
Mechanical Design						
height		90 mm				
width		72 mm				
depth		70 mm				
installation depth		70 mm				
number of modular width units		4				
fastening method		DIN rail (REG)				
mounting position		any				
grid spacing		60 mm				
net weight		362 g				
Environmental conditions						
ambient temperature during operation						
• minimum		-5 °C	-5 °C			
• maximum		45 °C				
ambient temperature during storage minimum		-40 °C				
number of test cycles for environmental testing according to IEC 60068-2-30		28				
General Product Approval	other			Dangerous Good	Environment	
<u>Confirmation</u>	<u>Confirmatic</u>	<u>on</u>	<u>Miscellaneous</u>	Transport Information	Environmental Con- firmations	

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SV5646-6

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SV5646-6

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SV5646-6

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications

last modified:

8/15/2023 🖸